


ETR


Detailplan SS-1040
detail plan/plan détaillé



ETR / EDR →
Setpoint 1/2
10 ..24 VDC (extern)

HQD EC ..., HWD EC ...

EC-Motor, zu / to / en SS-1203




- Störmeldung, siehe MBV
- fault signal, see instruction
- Alerte de défaut, voir instruction

! Steuerleitungen max. 30m, ab 20m abgeschirmt, siehe Montage- und Betriebsvorschrift !
control cables max. 30m, shielded from 20m, see Installation and Operating Instruction !
Cables de commande max. 30m, blindés à partir de 20m, voir Notice d'installation et de montage !

EDR

Detailplan SS-1039
detail plan/plan détaillé



Setpoint 1/2
10 ..24 VDC (extern)

HRFD EC ... EC-Motor, zu / to / en SS-1203

