



KWLC 1800 EH

Anschluss **externe** Komponenten / Connection of external components



Geräte **interne** Komponenten / Inside components



1. Switch with clock timer

2. Remote display

3. Supply line - minimum, dependig on the kind of permanent

4. Smoke / Fire sensor - potential free contact

5. Alternatively external - lowering of fan speed - potential free contact

6. Unit off - potential free contact

7. Optional room air temperature sensor

8. Alarm, potential free contact

9. Supply air, back draught shutter

10. Extract air, back draught shutter

14. Frost protection sensor in heat exchanger / extract air

15. Poti for temperatur set point

17. Supply air motor

18. Extract air motor

19. Bypass flap in front of heat exchanger

20. Supply air duct temperature sensor

21. Thermal cutout with manual reset

22. Thermal cutout with automatic reset

23. Filter control outside air

24. Filter control extract air

25. Pressure control for outside / supply air fan

26. Fan cooling control box

27. Heating rods