






ELS-VPC ...

○ ○ ○ ○ ○
1 2 3 L N



DIP-Schalter / Switch / Commutateur

			1	2	3	4	5
	Intervall aktiv / inaktiv Interval time on / off Durée intervalle marche / arrêt	inaktiv	off	—	—	—	—
		aktiv	on	—	—	—	—
 	Nachlauf / Einschaltzeit Run on time / Running time Temporisation / Durée de fonctionnement	5 min	—	off	off	—	—
		10 min	—	off	on	—	—
		15 min	—	on	off	—	—
		20 min	—	on	on	—	—
	Intervallzeit, Einschaltdauer= Nachlaufzeit Interval time Running time = Run on time Durée intervalle Durée de fonctionnement = Temporisation	4 Std	—	—	—	off	off
		8 Std	—	—	—	off	on
		12 Std	—	—	—	on	off
		24 Std	—	—	—	on	on