




Dimensions BAE BAE Dim. in mm see table



Application

Damper element to prevent the spread of fire and smoke. For installation in ventilation shafts and ducts with the required fire resistance class K 90-18017. Suitable for insertion in spiral ducts or for installation in walls and non-fire-resistant suspended ceilings using installation sleeve EH (accessories) as well as in fire-resistant ceilings as ceiling seals.

Function

When an air temperature of +72 °C is exceeded, the integrated fusible link releases the semicircular damper blades which close abruptly by spring force. Two safety brackets lock the shutters.

Official approval

The proof of suitability of this damper element for ventilation systems according to DIN 18017 has been provided by means of appropriate tests. General technical approval from the DIBt with no. Z-41.3-696.

Special features

- $\hfill \square$ No maintenance conditions.
- Cleaning and inspection together with the associated ventilation system.
- Insertion in spiral ducts without additional brickwork frame.

- Installation outside of the shaft wall is possible.
- Any air flow direction, i.e. for supply air and extract air.
- Low flow resistance, even at high air flow rates.
- Connection to fume extractor or extraction hood is possible.
- □ Low-noise.
- Application in residential and commercial areas, e.g. internal toilets, kitchenettes, etc.

Design

Cylindrical duct sleeve with butterfly valve and integrated fusible link.

Delivery

Shrink-wrapped in plastic film.

Installation and setting

- The installation and operating instructions contain exact specifications with regard to application and installation.
- ☐ The specifications in the related approval must be observed.

Accessories

End switch

For BAE monitoring and signalling the operating status to the central building management system. Attachable to all ND, simple snap-in installation.

BA-S Ref. no. 02585 Switch as changeover contact IP67 Max. load 5 – 250 V / 6 A (2 A ind.) Connect. cable 50 cm long / 3 x 0.34 mm² Wiring diagram no. 830

Installation examples

Duct installation

The element is installed by simple insertion (e.g. in spiral ducts) and fixed in the wall together with the duct.

Installation is possible on both sides, regardless of the air flow direction.


■ Wall installation

With installation sleeve EH (accessories) in walls made from brickwork, aerated concrete or plasterboard, shaft partition walls in F 90 and F 30 or systemtested walls over 40 mm thick. Installation is possible on both sides, regardless of the air flow direction.

Ceiling installation

- Possible in non-fire-resistant suspended ceilings.
- In fire-resistant ceilings as ceiling seal if no free cross-section is required.





Wall installation with installation sleeve or spiral duct and inserted supply/extract air element.



Order data										
					Accessories:					
Туре	Ref. Dim. in mn		n mm	Weight	Installatio	on Ref.	Dimensions in mm			
	no.	ØΑ	В	aprx. kg	sleeve	no.	ØС	Ø D	Е	F
BAE 80	02624	78	60	0.17						
BAE 100	02625	98	60	0.23	EH 100	02639	100	98	110	140
BAE 125	02626	123	60	0.30	EH 125	02640	125	123	110	140
BAE 160	02627	158	60	0.40	EH 160	02641	160	158	110	140
BAE 200	02628	198	60	0.55	EH 200	02642	200	198	110	140