

Schalterbetrieb (kombiniert mit Raumlicht)





Switch operation (combined with light)

Service commutateur (combiné avec lumière)

Tasterbetrieb (separate Ansteuerung)

Push-button switch operation (separate control)

Service bouton de touche (excitation séparée)



Ausschaltimpuls min. 1,5 sec.
Breaking impulse min. 1,5 sec.
Impulsion de coupure
min. 1,5 sec.

Bedarfslüftung / ventilation according to requirements / aération selon besoins

Klappe / shutter / clapet

Grundlüftung / basic ventilation / aération de base